

SIMPLEX TRANSMITTER ORDERING INFORMATION





optical technologies

7444 West Wilson Avenue • Chicago, IL 60656 (708) 867-9600 • (800) 323-6858 • Fax: (708) 867-0996 email:optoinfo@stratoslightwave.com http://www.stratoslightwave.com

FEATURES:

- SMPTE 292M/297M/259M/305M compliant (VMC-T-H-2)
- SMPTE 259M/297M/305M compliant (VMC-T-S-2)
- DVB/ASI compliant (VMC-T-H-2 and VMC-T-S-2)
- ATSC/SMPTE 310M compliant; 19.4 to 38.8Mbps (VMC-T-H-2 and VMC-T-S-2)
- Rugged die cast/over molded construction
- Digital Diagnostics Monitoring Interface
- Unit to unit pitch (Port Density) of 0.75"
- Rugged "ST" simplex optical interface
- Line Equalized 75Ω BNC (male) simplex electrical interface
- Error free pathological pattern operation
- Typical wall plug or 12V battery supply (+4.5V to +16V)
- LED indicator (See Table below)
- LED legend code on unit
- Red overmold to distinguish from receiver (blue) unit
- Accessories available
- "ST" Dust cover included (Not shown)
- Class 1 Laser Safety compliant

PRODUCT OVERVIEW

The VMC-T-X-2 media converter transmitter module is a high performance integrated data link for uni-directional communication over single mode fiber. The VMC-T-S-2 is designed to be used in SMPTE 259M/297M/305M/310M applications with data rate up to 540Mbps. The VMC-T-H-2 is designed to be used in multi-protocol video applications with data transfer rate up to 1.485Gbps (SMPTE 292M/297M/259M/305M/310M). The media converter module is designed to connect to electrical high speed serial digital video links that require extended distance performance. It permits replacement of copper cable with optical fiber to provide a solution for systems requiring increased media interconnect distance.

DIGITAL DIAGNOSTICS MONITORING INTERFACE

The VMC-T-X-2 is offered with Digital Diagnostics Monitoring Interface (DDMI) which allows real-time access to device operating parameters such as module temperature, laser bias current, transmitted optical power and module supply voltage. It also defines a system of alarm flags, which alert end-users when particular operating parameters are outside of a factory set normal range.

LED INDICATOR

STATUS	CONDITION
Green	Normal Operation
Red	Transmit Fault
Blinking Green	No Cable Connected
Blinking Red	DDMI Alarm
Blinking Orange	DDMI Warning

RECOMMENDED OPERATING CONDITIONS

PARAMETER	SYMBOL	MIN	MAX	UNITS	NOTES			
Operating Case Temperature	Tc	-30	+70	°C				
Supply Voltage	Vcc	+4.5	+16	VDC	Typical Wall plug/ 12V battery 16V charging level			
Power Dissipation			1.0	W				
Baud Rate	Brate	19.4	540	Mhns	VMC-T-S-2; 19.4/143/177/270/360/540Mbps			
	Didie	19.4	1485	Mopo	VMC-T-H-2; 19.4/143/177/270/360/540/1485Mbps			

ELECTRICAL SPECIFICATIONS

PARAMETER	SYMBOL	MIN	TYP	MAX	UNITS	NOTES
Input Signal		SMPTE	259M/29	7M/292M	тVpp	
Input Impedance	Z _{IN}		75		Ohms	Male BNC (note 1)
Return Loss		15			dB	
Propagation Delay				1.5	ns	

VMC-T-X-2 OPTICAL SPECI	-30°C <tc<+70°c< th=""></tc<+70°c<>					
PARAMETER	SYMBOL	MIN	TYP	MAX	UNITS	NOTES
LINK DISTANCES						
0.0um Coro Diamotor SME (Note 2)		12	24		km	BER<1E-10 @ 360/540/1485Mbps
		15	30		km	BER<1E-10 @ 143/177/270Mbps
TRANSMITTER						
Optical Center	λ	1290	1310	1330	nm	
Optical Transmit Power	Popt	-12		-7.5	dBm	Average @ 1310nm
Extinction Ratio	ER	5	10		dB	P1/P0
Spectral Width	Δλ			4	nm	RMS
				135	ne	Measured with Color Bar Test Signal
Total Jitter	T.I			155	ps	@1.485Gbps)
	10			740	ne	Measured with Color Bar Test Signal
				740	ps	@143/177/270/360/540Mbps)
				270	ne	20%-80%; Measured unfiltered
Output Rise/Fall Time	+ +			270	μs	@1.485Gbps)
	чR, чF	0.4		1.5	20	20%-80%; Measured unfiltered
		0.4		1.5	115	@143/177/270/360/540Mbps)

Note 1: Equalized for 140m Beldon 1694A @ 1.485Gb/s and 350m Beldon 1694A @ 270Mb/s

Note 2: Assumes minimum transmitter output power of -12dBm with minimum extinction ratio of 9dB over 9/125µm Single Mode Fiber (SMF) at 140/177/270/360/540/1485Mbps. The minimum link distances are based on worst case receiver sensitivity (VMC-R-X-2 simplex receiver video media converter) with color bar test signal. The minimum link distances will be reduced with SDI test matrix.

DIGITAL DIAGNOSTIC MONITORING INTERFACE ---- Simplex Transmitter

The media converter modules are provided with internally calibrated digital diagnostic monitoring interface which allows real-time access to device operating parameters such as module temperature, laser bias current, transmitted optical power, and module supply voltage. It also defines a system of alarm flags, which alerts end-users when particular operating parameters are outside of a factory set normal range.



The VMC-T-X-2 Digital Diagnostics Monitorint Interface (DDMI) memory map is shown in figure 1 below.

Figure 1: Simplex Transmitter Media Converter DDMI Memory Map

2-WIRE SERIAL INTERFACE CHARACTERISTICS

Table below describes the requirements for devices connected to the 2-wire serial bus.

SYMBOL	PARAMETER	MIN	MAX	UNITS
V _{IL}	Input Low-Voltage	-0.5	1.0	V
V _{IH}	Input High-Voltage	2.3	3.8	V
V _{HYS}	Hysteresis of Schmitt Trigger Inputs	0.165	-	V
V _{OL}	Output Low-Voltage	0	0.4	V
t _F	Rise Time for both SDA and SCL	-	300	ns
t _{OF}	Output Fall time from V _{IHmin} to V _{ILmax}	-	250	ns
t _{SP}	Spikes suppressed by input filter	0	50	ns
li	Input current each I/O pin	-10	10	μA
C _i	Capacitance for each I/O pin	-	15	pF
f _{SCL}	SCL Clock Frequency	0	100	KHz
R _P	Value of Pull-Up resistor	-	10	KΩ
t _{HD;STA}	Hold Time (repeated) START Condition	4.0	-	μs
t _{LOW}	Low Period of SCL Clock	4.7	-	μs
t _{HIGH}	High Period of SCL Clock	4.0	-	μs
t _{SU;STA}	Set-Up time for a repeated Start Condition	4.7	-	μs
t _{HD;DAT}	Data hold time	0	3.45	μs
t _{SU;DAT}	Data set-up time	250	-	ns
t _{SU;STO}	Setup time for STOP condition	4.0	-	μs
t _{BUF}	Bus free time between a STOP and START condition	4.7	-	μs

SERIAL IDENTIFICATION (2-wire address A3h)

The VMC-T-X-2 media converter transmitter module provides access to sophisticated identification information that describes its capabilities, manufacturer and other information. The serial interface uses the 2-wire serial CMOS E2PROM. The memories are organized as a series of 8-bit data words that can be addressed individually or sequentially.

Addr. (Dec)	Description	Specification	Data (hex)	Specification	Data (hex)
		VMC-T-H-2 (HD)		VMC-T-S-2 (SD)	
0	Identifier	VMC BNC-to-Fiber Transmitter	01	VMC BNC-to-Fiber Transmitter	01
1	Host Connector	Male BNC	01	Male BNC	01
2	Transport Connector	ST	01	ST	01
3	SMPTE Data Rates	143,177,270,360,540,1485Mb/s	FC	143,177,270,360,540Mb/s	F8
4	SD Reach		00	Intra-Facility	01
5	Laser	Laser 1310nm	02	Laser 1310nm	02
6	BR in 10 Mbps	149	95	27	1B
7	Wavelength MSB	1310nm	05	1310nm	05
8	Wavelength LSB	13101111	1E	13101111	1E
9	Encoding	SMPTE Scramble	01	SMPTE Scramble	01
10	Length(9µ) * km	12	0C	15	0F
11	Length(50µm) * 10m	0	00	0	00
12	Length(62.5µm) * 10m	0	00	0	00
13	Length (copper) * 1m	0	00	0	00
14		S	53	S	53
15		t	74	t	74
16		r	72	r	72
17		а	61	а	61
18		t	74	t	74
19		0	6F	0	6F
20		S	73	S	73
21		Space	20	Space	20
22	Vendor Name	Space	20	Space	20
23		Space	20	Space	20
24		Space	20	Space	20
25		Space	20	Space	20
26		Space	20	Space	20
27		Space	20	Space	20
28		Space	20	Space	20
29	•	Space	20	Space	20
30	•	Space	20	Space	20
31		V	56	V	56
32		М	4D	М	4D
33	•	С	43	С	43
34		-	2D	-	2D
35	V and an Dart Number	Т	54	Т	54
36	vendor Part Number	-	2D	-	2D
37	t	Н	48	S	53
38	•	-	2D	-	2D
39	•	2	32	2	32
40	•	Space	20	Space	20
			-		-

Table D.1a (1of 2): Serial ID Data Fields (2-wire Address A3h)

SERIAL IDENTIFICATION (2-wire address A3h) Continue:

VMCT-H-2 (HD) VMCT-S-2 41 Space 20 Space 20 41 Vendor Patt Space 20 Space 20 43 Vendor Patt Space 20 Space 20 44 Number Space 20 Space 20 44 Number Space 20 Space 20 45 Space 20 Space 20 46 Space 20 Space 20 47 Space 20 Space 20 48 Vendor Rev. 20 Space 20 49 Reserved 00 00 00 50 Reserved 00 00 00 51 TX Options Disable, Fault, EqBypass, Cable Det E8 Disable, Fault, EqBypass, Cable Det E8 55 XX XX XX XX 56 XX XX XX 56 XX	Addr (Dec)	Description	Specification	Data (hex)	Specification	Data (hex)		
41 42 43 44 44 44 44 44 44 44 44 44 44 44 44			VMC-T-H-2 (HD)	VMC-T-S-2				
42 3 44Vendor Part NumberSpace20Space2043 44NumberSpace20Space2045 46Space20Space2046Space20Space2047Space20Space2048Vendor Rev.20Space2049Reserved00Space2049Reserved00000050Reserved00000051Roserved00000052Reserved00Not Applicable0053TXOptionsNot Applicable00Not Applicable56SpaceXXInconsectiveXX57SpaceXXInconsective56SpaceXXInconsectiveXX56InconsectiveXXInconsective57SpaceXXInconsectiveXX56InconsectiveXXInconsective57InconsectiveXXInconsectiveXX56InconsectiveXXInconsectiveXX56InconsectiveXXInconsectiveXX56InconsectiveXXInconsectiveXX56InconsectiveXXInconsectiveXX56InconsectiveXXInconsectiveXX56InconsectiveXXInconsectiveXX56InconsectiveXX<	41		Space	20	Space	20		
43 NumberVendor Part SpaceSpace20Space201Space20Space2046Space20Space2047Space20Space2048Vendor Rev.20Space2049Reserved20Space2049Reserved00000050Reserved00000051Reserved00000052Reserved00000053TX OptionsDisable, Fault, EqBypass, Cable DetE854RX OptionsDisable, Fault, EqBypass, Cable DetE855StateXXNot Applicable56StateXXXX58StateXX58StateXX56XXIncomental XX56XXIncomental XX56XXIncomental XX57XXXX58Incomental XX58Incomental XX58Incomental XX58Incomental XX59Incomental XX56XX57Incomental XX58Incomental XX59Incomental XX50Incomental XX50Incomental XX51Incomental XX52Incomental XX53Incomental XX54Incomental XX55Incomental XX56Income	42		Space	20	Space	20		
44 Ventor Part Space 20 Space 20 45 Space 20 Space 20 46 Space 20 Space 20 47 Space 20 Space 20 48 Vendor Rev. 20 Space 20 49 Reserved 00 00 00 50 Reserved 00 00 00 51 Reserved 00 00 00 52 Reserved 00 00 00 53 TX Options Disable, Fault, EqBypass, Cable Det E8 Disable, Fault, EqBypass, Cable Det E8 54 RX Options Not Applicable 00 Not Applicable 00 55 State XX XX XX XX 56 XX Image: Sate Sate Sate Sate Sate Sate Sate Sate	43	Vondor Part	Space	20	Space	20		
45 Number Space 20 Space 20 46 Space 20 Space 20 47 Space 20 Space 20 48 Vendor Rev. 20 Space 20 49 Reserved 00 00 00 50 Reserved 00 00 00 51 Reserved 00 00 00 52 Reserved 00 00 00 53 TXOptions Disable, Fault, EqBypass, Cable Det E8 Not Applicable 00 54 RX Options Not Applicable XX XX XX 56 XX Image: Applicable XX XX	44	Number	Space	20	Space	20		
46 Space 20 Space 20 47 Space 20 Space 20 48 Vendor Rev. 200 20 20 49 Reserved 00 20 20 49 Reserved 00 00 20 50 Reserved 00 00 00 51 Reserved 00 00 00 52 Reserved 00 00 00 53 TX Options Disable, Fault, EqSypass, Cable Det E8 Disable, Fault, EqSypass, Cable Det E8 54 RX Options Not Applicable 00 Not Applicable 00 55 XX XX XX 56 XX XX XX 56 XX XX XX 56 XX XX XX 56 XX XX XX	45	Number	Space	20	Space	20		
47Space20Space2048Vendor Rev.202049Reserved000050Reserved000051Reserved000052Reserved000053TX OptionsDisable, Fault, EqBypass, Cable DetE854RX OptionsNot Applicable0056XXXX57XXXX58(Not Applicable)XX59(Not Applicable)XX59(Not Applicable)XX50(XX)(XX)51(XX)(XX)52(XX)(XX)53(XX)(XX)54(XX)(XX)55(XX)(XX)56(XX)(XX)57(XX)(XX)58(XX)(XX)54(XX)(XX)55(XX)(XX)56(XX)(XX)57(XX)(XX)58(XX)(XX)59(XX)(XX)54(XX)(XX)55(XX)(XX)56(XX)(XX)57(XX)(XX)58(XX)(XX)59(XX)(XX)50(XX)(XX)51(XX)(XX)52(XX)(XX)53(XX)(XX)54(XX)(XX)55(XX)(XX)5	46		Space	20	Space	20		
48 Vendor Rev. 20 20 49 Reserved 00 00 50 Reserved 00 00 51 Reserved 00 00 52 Reserved 00 00 53 TX Options Disable, Fault, EqBypass, Cable Det E8 54 RX Options Not Applicable 00 55	47		Space	20	Space	20		
49Resened000050Reserved000051Reserved000052Reserved000053TX OptionsDisable, Fault, EqBypass, Cable DetE854RX OptionsNot Applicable00Not Applicable55	48	Vendor Rev.		20		20		
50Reserved000051Reserved000052Reserved000053TX OptionsDisable, Fault, EqBypass, Cable DetE854RX OptionsNot Applicable0056XXXX56XXXX57XXXX58XXXX58XXXX59XXXX50XXXX50XXXX50XXXX51XXXX52XXXX53XXXX54XXXX55XXXX56XXXX57XXXX58XXXX59XXXX54XXXX55XXXX56XXXX56XXXX57XXXX58XXXX59XXXX50XXXX50XXXX51XXXX52XXXX53XXXX54XXXX55XXXX56XXXX57XXXX58XXXX59XXXX50XXXX50XXXX51XXXX52XXXX53 <td>49</td> <td>Reserved</td> <td></td> <td>00</td> <td></td> <td>00</td>	49	Reserved		00		00		
51Reserved000052Reserved000053TX OptionsDisable, Fault, EqBypass, Cable DetE854RX OptionsNot Applicable0055XXXX56XXXX57XXXX58XXXX59XXXX60XXXXXX60XXXXXX61XXXXXX62XXXX63XXXX64XXXX65XXXX66XXXX66XXXX67XX68XX69XX70 </td <td>50</td> <td>Reserved</td> <td></td> <td>00</td> <td></td> <td>00</td>	50	Reserved		00		00		
52Reserved00000053TX OptionsDisable, Fault, EqBypass, Cable DetE8Disable, Fault, EqBypass, Cable DetE854RX OptionsNot Applicable00Not Applicable0055	51	Reserved		00		00		
53TX OptionsDisable, Fault, EqBypass, Cable DetE8Disable, Fault, EqBypass, Cable DetE854RX OptionsNot Applicable00Not Applicable0056XXXXXXXX57XXXXXX58XXXXXX59XXXXXX60XXXXXX61XXXXXX62XXXXXX63XXXXXX64XXXXXX65XXXXXX66XXXXXX67XXXXXX68XXXXXX69XXXXXX70XXXXXX71XXXXXX73XXXXXX74XXXXXX75XXXXXX78XXXXXX79CC_Serial IDXXXX80Reserved00XXXX	52	Reserved		00		00		
54RX OptionsNot Applicable00Not Applicable0055565758585959505657585959595051525354545555555656565656565656565656565656565757585959505051525354555556565757585959505050515253545455<	53	TX Options	Disable, Fault, EqBypass, Cable Det	E8	Disable, Fault, EqBypass, Cable Det	E8		
55 XX XX 56 XX XX 57 XX XX 58 XX XX 59 XX XX 60 XX XX 61 XX XX 62 XX XX 63 XX XX 64 XX XX 65 XX XX 66 XX XX 67 XX XX 68 XX XX 66 XX XX 67 XX XX 68 XX XX 69 XX XX 70 XX XX 71 XX XX 72 XX XX 73 XX XX 74 XX XX 75 XX XX 76 XX XX 77 XX XX 78 <	54	RX Options	Not Applicable	00	Not Applicable	00		
56 XX XX 57 XX XX 58 XX XX 59 XX XX 60 XX XX 61 XX XX 62 XX XX 63 XX XX 64 XX XX 65 XX XX 66 XX XX 66 XX XX 66 XX XX 67 XX XX 68 XX XX 69 XX XX 70 XX XX 71 XX XX 72 XX XX 73 XX XX 74 XX XX	55			XX		XX		
57 XX XX 58 XX XX 59 XX XX 60 XX XX 61 XX XX 62 XX XX 63 XX XX 64 XX XX 65 XX XX 66 XX XX 67 XX XX 68 XX XX 69 XX XX 70 XX XX 71 XX XX 73 XX XX 74 XX XX 75 XX XX 76 XX XX	56			XX		XX		
58 59 59 60 59 60 59 61 59 61 59 61 59 62 50 53 50 63 50 64 50 65 50 66 50 66 50 66 50 67 50 68 50 69 50 70 50 71 70 72 73 73 74 74 74 75 76 77 77 78 79 79 CC_Serial ID 79 CC_Serial ID 70 70	57	l I		XX		XX		
59 Kan	58			XX		XX		
60 XX XX 61 XX XX 62 Number XX XX 63 Number XX XX 64 XX XX XX 65 XX XX XX 66 XX XX XX 67 XX XX XX 68 XX XX XX 69 XX XX XX 70 XX XX XX 71 XX XX XX 73 XX XX XX 73 XX XX XX 74 XX XX XX 75 XX XX XX 76 XX XX XX <td>59</td> <td></td> <td></td> <td>XX</td> <td></td> <td>XX</td>	59			XX		XX		
61 62 NumberVendor Serial NumberXXXX 63 64 NumberXXXX 64 XXXX 65 XXXX 66 XXXX 66 XXXX 67 XXXX 68 XXXX 69 XXXX 70 XXXX 71 XXXX 71 XXXX 71 XXXX 71 XXXX 73 XXXX 74 XXXX 74 XXXX 74 XXXX 74 XXXX 74 XXXX 75 XXXX 76 XXXX 77 XXXX 78 XXXX 79 CC_Serial IDXX 80 Reserved00	60			XX		XX		
62Vendor Serial NumberXXXX63NumberXXXX64XXXXXX65XXXXXX66XXXXXX67XXXXXX68XXXXXX69XXXXXX69XXXXXX70XXXXXX71XXXXXX71XXXXXX71XXXXXX73XXXXXX74XXXXXX73XXXXXX74XXXXXX75XXXXXX76XXXXXX77XXXXXX78XXXXXX79CC_Serial IDXXXX80Reserved0000	61	l I		XX		XX		
63 Number XX XX 64 XX XX 65 XX XX 66 XX XX 67 XX XX 68 XX XX 69 XX XX 70 XX XX 71 XX XX 72 XX XX 73 XX XX 74 XX </td <td>62</td> <td>Vendor Serial</td> <td></td> <td>XX</td> <td></td> <td>XX</td>	62	Vendor Serial		XX		XX		
64 XX XX XX 65 XX XX XX 66 XX XX XX 67 XX XX XX 68 XX XX XX 69 XX XX XX 70 XX XX XX 71 XX XX XX 71 XX XX XX 71 XX XX XX 73 XX XX XX 74 Date Code XX XX XX 76 XX XX XX XX 77 XX XX XX XX 78 XX XX XX XX 79 CC_Serial ID XX <td>63</td> <td>Number</td> <td></td> <td>XX</td> <td></td> <td>XX</td>	63	Number		XX		XX		
65 XX XX XX 66 XX XX XX 67 XX XX XX 68 XX XX XX 69 XX XX XX 70 XX XX XX 70 XX XX XX 71 XX XX XX 73 XX XX XX 73 XX XX XX 74 Date Code XX XX XX 76 XX XX XX XX 77 XX XX XX XX 78 XX XX XX	64			XX		XX		
66 XX XX XX 67 XX XX XX 68 XX XX XX 69 XX XX XX 70 XX XX XX 70 XX XX XX 71 XX XX XX 73 XX XX XX 73 XX XX XX 74 Date Code XX XX XX 75 XX XX XX XX 76 XX XX XX XX 78 XX XX XX XX 79 CC_Serial ID XX XX XX 79 Reser	65	ľ		XX		XX		
67 58 50<	66			XX		XX		
68 XX XX XX 69 XX XX XX 70 XX XX XX 70 XX XX XX 71 XX XX XX 71 XX XX XX 72 XX XX XX 73 XX XX XX 73 XX XX XX 74 Date Code XX XX 75 XX XX XX 76 XX XX XX 76 XX XX XX 77 XX XX XX 78 XX XX XX 79 CC_Serial ID XX XX XX 80 Reserved 00 00 00	67			XX		XX		
69XXXX70XXXX71XXXX71XXXX72XXXX73XXXX74AXXX74AXXX75XXXX76XXXX77XXXX78XXXX79CC_Serial IDXX80Reserved00	68			XX		XX		
70XXXX71727273737474757676777879707070717273747576777879797070707172737474757677777879707070717273747475757677787970717172737474757575757675767778797070707070707070717273747575757575767677787970707070707070<	69	Ē		XX		XX		
71XXXX72XXXX73XXXX74XXXX75XXXX76XXXX77XXXX78XXXX79CC_Serial IDXX80Reserved00	70			XX		XX		
7273XXXX7374XXXX740ate CodeXXXX75XXXXXX76XXXXXX77XXXXXX78XXXXXX79CC_Serial IDXXXX80Reserved0000	71			XX		XX		
7374Date CodeXXXX75Date CodeXXXXXX76XXXXXX77XXXXXX78XXXXXX79CC_Serial IDXXXX80Reserved0000	72			XX		XX		
74 75Date CodeXXXX76XXXX76XXXX77XXXX78XXXX79CC_Serial IDXX80Reserved00	73	ľ		XX		XX		
75 XX XX 76 XX XX 77 XX XX 78 XX XX 79 CC_Serial ID XX 80 Reserved 00 00	74	Data Cada		XX		XX		
76 XX XX 77 XX XX 78 XX XX 79 CC_Serial ID XX 80 Reserved 00 00	75			XX		XX		
77 XX XX 78 XX XX 79 CC_Serial ID XX 80 Reserved 00 00	76	F F		XX		XX		
78 XX XX 79 CC_Serial ID XX XX 80 Reserved 00 00	77	F F		XX		XX		
79 CC_Serial ID XX XX 80 Reserved 00 00	78	F F		XX		XX		
80 Reserved 00 00	79	CC_Serial ID				XX		
	80	Reserved		00		00		

"XX" denotes hex value which varies with each module.

Table D.1b (2of 2): Serial ID Data Fields (2-wire Address A3h)

DIGITAL DIAGNOSTIC (2-wire address A3h)

This portion of the memory map contains real-time measurements of VMC-T-X-2 module temperature, laser bias current, transmitted optical power, and module supply voltage. The real-time diagnostics registers are shown in table D.2 below. The VMC-T-X-2 media converter modules are internally calibrated which means that the modules directly reports calibrated values in units of current, power, etc.

Data Address	Bit	Name	Description
81	All	Temperature MSB	Internally measured module temperature
82	All	Temperature LSB	
83	All	Vcc MSB	Internally measured supply voltage in simpley transmitter module
84	All	Vcc LSB	internally measured supply whage in simplex transmitter module
85	All	TX Bias MSB	Internally measured TX Bias current
86	All	TX Bias LSB	
87	All	TX Power MSB	Measured TX output nower
88	All	TX Power LSB	
89	All	RX Power MSB	Not programmed in Simpley Transmitter Module
90	All	RX Power LSB	
91	All	CLI MSB	Cable Longth Indicator
92	All	CLILSB	
93-94	All	Reserved	Reserved

Table D.2: Real-time diagnostic registers (2-wire address A3h)

Measurements are calibrated over vendor specified operating temperature and voltage and should be interpreted as defined below. Alarm and warning threshold values should be interpreted in the same manner as real time 16 bit data.

1) Internally measured simplex transmitter temperature: Represented as a 16 bit signed twos complement value in increments of 1/256 degrees Celsius, yielding a total range of -128C to +128C. Temperature accuracy is better than ± 3 degrees Celsius over specified operating temperature and voltage. The temperature in degrees Celsius is given by the signed twos complement value with LSB equal to 1/256 C. See Tables D.3a and D.3b for examples of temperature format.

2) Internally measured simplex transmitter supply voltage: Represented as a 16 bit unsigned integer with the voltage defined as the full 16 bit value (0 – 65535) with LSB equal to 100 μ Volt, yielding a total range of 0 to +6.55 Volts. Accuracy is better than ±3% of the nominal value over specified operating temperature and voltage.

3) Measured TX bias current in μ A. Represented as a 16 bit unsigned integer with the current defined as the full 16 bit value (0 – 65535) with LSB equal to 2 μ A, yielding a total range of 0 to 131 mA. Accuracy is better than ±10% of the nominal value over specified operating temperature and voltage.

4) Measured TX output power in mW: Represented as a 16 bit unsigned integer with the power defined as the full 16 bit value (0 – 65535) with LSB equal to 0.1 μ W, yielding a total range of 0 to 6.5535 mW (~ -40 to +8.2 dBm). Data is assumed to be based on measurement of laser monitor photodiode current. It is factory calibrated to absolute units using the most representative fiber output type. Accuracy is better than ±3dB over specified temperature and voltage. Data is not valid when the transmitter is disabled.

DIGITAL DIAGNOSTIC (2-wire address A3h) -- Continue

TEMPERATURE REPORTING:

Tables D.3a and D.3b illustrate the 16 bit signed two complement format used for temperature reporting. The most significant bit (D7) represents the sign, which is zero for positive number and one for negative number.

	Most Significant Byte (Data A	ddress	;			
D7	D6	D5	D4	D3	D2	D1	D0	D7	D6	D5	D4	D3	D2	D1	D0
Sign	64	32	16	8	4	2	1	1/2	1/4	1/8	1/16	1/32	1/64	1/128	1/256

Tempe	erature	Bin	ary	Hexadecimal		
Decimal	Fraction	HIGH byte	LOW byte	HIGH byte	LOW byte	
+127.996	+127 255/256	01111111	11111111	7F	FF	
+125.000	+125	01111101	0000000	7D	00	
+25.000	+25	00011001	00000000	19	00	
+1.004	+1 1/256	0000001	0000001	01	01	
+1.000	+1	0000001	0000000	01	00	
+.996	+255/256	0000000	11111111	00	FF	
+0.004	+1/256	0000000	0000001	00	01	
0.000	0	0000000	0000000	00	00	
-0.004	-1/256	11111111	11111111	FF	FF	
-1.000	-1	11111111	0000000	FF	00	
-25.000	-25	11100111	0000001	E7	00	
-40.000	-40	11011000	0000002	D8	00	
-127.996	-127 255/256	1000000	0000001	80	01	
-128.000	-128	1000000	00000000	80	00	

Table D.3A: Bit weights (°C) for temperature reporting registers

 Table D.3B: Digital temperature format

DIGITAL DIAGNOSTICS Continue (2-wire address A3h) ALARM and WARNING FLAGS:

Data address 95-98 (Table D.4) contain an optional set of alarms and warnings. The alarm/warning flags are not latched. It is recommended that the detection of an asserted flag bit should be verified by a second read of the flag at least 100msec later. For users who do not wish to set their own threshold values (address 102-159 at 2-wire address A2h) or read the values (address 102-159 at 2-wire address A3h), the flags alone can be monitored.

Alarm/warning flags which are associated with simplex transmitter modules are temperature, supply voltage, TX bias, TX output power, and Cable Length indicator (CLI). Alarm/warning flags indicate conditions likely to be associated with an in-operational link and cause for immediate action.

Data Address	Bits	Name	Description	Value (VMC-T-H-2/ VMC-T-S-2)
	7	Temp High Alarm	Set when internal temperature exceed high alarm level	+95℃
	6	Temp Low Alarm	Set when internal temperature is below low alarm level	-30°C
	5	Temp High Warning	Set when internal temperature exceed high warning level	+90°C
95	4	Temp Low Warning	Set when internal temperature is below low warning level	-25°C
30	7	Voltage High Alarm	Set when internal supply Voltage exceed high alarm level	+3.7V
	6	Voltage Low Alarm	Set when internal supply Voltage is below low alarm level	+2.9V
	5	Voltage High Warning	Set when internal supply Voltage exceed high warning level	+3.65V
	4	Voltage Low Warning	Set when internal supply Voltage is below low warning level	+3.00V
	7	TX_BIAS High Alarm	Set when internal TX_Bias current exceed high alarm level	35mA
	6	TX_BIAS Low Alarm	Set when internal TX_Bias current is below low alarm level	0mA
	5	TX_BIAS High Warning	Set when internal TX_Bias current exceed high warning level	30mA
96	4	TX_BIAS Low Warning	Set when internal TX_Bias current is below low warning level	0.3mA
30	3	TX_PWR High Alarm	Set when internal TX output power exceed high alarm level	-7.5dBm
	2	TX_PWR Low Alarm	Set when internal TX output power is below low alarm level	-12dBm
	1	TX_PWR High Warning	Set when internal TX output power exceed high warning level	-7.7dBm
	0	TX_PWR Low Warning	Set when internal TX output power is below low warning level	-11.8dBm
	7	RX_PWR High Alarm	Not programmed in Simplex Transmitter Module	
	6	RX_PWR Low Alarm	Not programmed in Simplex Transmitter Module	
97	5	RX_PWR High Warning	Not programmed in Simplex Transmitter Module	
	4	RX_PWR Low Warning	Not programmed in Simplex Transmitter Module	
	3-0	Reserved	Reserved	
98	7-0	Reserved	Reserved	

Table D.4: Alarm and Warning Flag Bits (2-wire Address A3h)

CONTROL/STATUS BITS (2-wire address A3h)

Data Address	Bits	Name	Description			
	7	TX_Disable State	Read			
	6	Soft TX_Disable	Read/Write			
	5	Cable Equalizer Bypass State	Read			
99	4	Soft Cable Equalizer Bypass	Read/Write			
	3	TX_FAULT	Read			
	2	Cable Detect	Read			
	1-0	Reserved				
	7	RX Mute state	Not applicable for simplex transmitter module			
	6	Soft RX mute	Not applicable for simplex transmitter module			
	5	SD/HD Indication	Read			
100	4	DVB/ASI Reclocker State	Not applicable for simplex transmitter module			
100	3	Soft DVB/ASI Reclocker	Not applicable for simplex transmitter module			
	2	Reclock Bypass state	Not applicable for simplex transmitter module			
	1	Soft Reclock Bypass	Not applicable for simplex transmitter module			
	0	Reclock Lock Det.	Not applicable for simplex transmitter module			
	7	Auto/Manual Reclock State	Not applicable for simplex transmitter module			
	6	Soft Auto/Manual Reclock	Not applicable for simplex transmitter module			
	5	2 Reclock Rate Det	Not applicable for simplex transmitter module			
101	4	1 Reclock Rate Det	Not applicable for simplex transmitter module			
101	3	0 Reclock Rate Det	Not applicable for simplex transmitter module			
	2	LOS	Not applicable for simplex transmitter module			
	1	Reserved				
	0	Data Ready Bar	Read			

Table D.5: Control/Status Bits (2-wire Address A3h)

ALARM/WARNING THRESHOLDS (2-wire address A3h)

Each A/D quantity has a corresponding high alarm/warning and low alarm/warning threshold. These factory preset values allow the user to determine when a particular value is outside of "normal" limits as determined by the transceiver manufacturer.

The VMC memory is read/writable as the write protect feature is not enabled. Thus, the host can change the factory set alarm threshold values (address 102-159 at 2-wire address A2h).

Data Address	# Bytes	Name	Description	
102-103	2	Temp High Alarm	MSB at Low Address	
104-105	2	Temp Low Alarm	MSB at Low Address	
106-107	2	Temp High Warning	MSB at Low Address	
108-109	2	Temp Low Warning	MSB at Low Address	
110-111	2	Voltage High Alarm	MSB at Low Address	
112-113	2	Voltage Low Alarm	MSB at Low Address	
114-115	2	Voltage High Warning	MSB at Low Address	
116-117	2	Voltage Low Warning	MSB at Low Address	
118-119	2	Bias High Alarm	MSB at Low Address	
120-121	2	Bias Low Alarm	MSB at Low Address	
122-123	2	Bias High Warning	MSB at Low Address	
124-125	2	Bias Low Warning	MSB at Low Address	
126-127	2	TX Power High Alarm	MSB at Low Address	
128-129	2	TX Power Low Alarm	MSB at Low Address	
130-131	2	TX Power High Warning	MSB at Low Address	
132-133	2	TX Power Low Warning	MSB at Low Address	
134-135	2	RX Power High Alarm	Not Applicable for simplex transmitter module	
136-137	2	RX Power Low Alarm	Not Applicable for simplex transmitter module	
138-139	2	RX Power High Warning	Not Applicable for simplex transmitter module	
140-141	2	RX Power Low Warning	Not Applicable for simplex transmitter module	
142-159	18	Reserved	Reserved	

Table D.6: Alarm and Warning Thresholds (2-wire address A3h)

USER WRITABLE MEMORY:

Data Address	# Bytes	Name	Description	
160-207	48	User EEPROM User Writable EEPROM		

Table D.7: User Accessible EEPROM (2-wire Address A2h)

Mechanical Dimensions (inches) ---- Weight: 2.5oz.



REGULATORY COMPLIANCE:

STANDARD	COMMENTS	
TUV	EN/IEC 60825 and EN/IEC 60950	
CDRH	FDA, CFR 21 Subchapter J	
UL/CSA	UL1950	
FCC	Subpart 15, Class A	

ACCESSORIES AVAILABLE:

(1) Wall Plug with Mini-XLR

Ordering information: VMC-PS-X

D = Domestic
 E = European
 U = U.K.
 A = Australia

Wall Plug Specification:

PARAMETER	Min	Мах	
Input Voltage	100V	240V	
Output Voltage (DC)	+5V @ 1000mA		





optical technologies 7444 West Wilson Avenue • Chicago, IL 60656 (708) 867-9600 • (800) 323-6858 • Fax: (708) 867-0996 email:optoinfo@stratoslightwave.com http://www.stratoslightwave.com

IMPORTANT NOTICE

Stratos Lightwave reserves the right to make changes to or discontinue any optical link product or service identified in this publication, without notice, in order to improve design and/or performance. Stratos Lightwave advises its customers to obtain the latest version of the publications to verify, before placing orders, that the information being relied on is current. Patents are pending.

Stratos Lightwave warrants performance of its optical link products to current specifications in accordance with Stratos Lightwave standard warranty. Testing and other quality control techniques are utilized to the extent that Stratos Lightwave has determined it to be necessary to support this warranty. Specific testing of all parameters of each optical link product is not necessarily performed on all optical link products.

Stratos Lightwave products are not designed for use in life support appliances, submarines, military, flight hardware, devices, or systems where malfunction of a Stratos Lightwave product can reasonably be expected to result in a personal injury. Stratos Lightwave customers using or selling optical link products for use in such applications do so at their own risk and agree to fully indemnify Stratos Lightwave for any damages resulting from such improper use or sale.

Stratos Lightwave assumes no liability for Stratos Lightwave applications assistance, customer product design, software performance, or infringement of patents or services described herein. Nor does Stratos Lightwave warrant or represent that a license, either expressed or implied is granted under any patent right, copyright, or intellectual property right , and makes no representations or warranties that these products are free from patent, copyright, or intellectual property rights.

Applications that are described herein for any of the optical link products are for illustrative purposes only. Stratos Lightwave makes no representation or warranty that such applications will be suitable for the specified use without further testing or modification.